

DALLAS LABORATORIES, INC.

Consultants and Technologists
Chemical and Petroleum Chemists

MEMBERS
AMERICAN CHEMICAL SOCIETY
ASTM INTERNATIONAL
AMERICAN SOCIETY OF MATERIALS

P.O. BOX 152837, DALLAS, TEXAS 75315
1323 WALL ST, DALLAS, TEXAS 75215
PHONE 214/565-0593
FAX 214/565-1094

MEMBERS
AMERICAN NATIONAL STANDARDS INSTITUTE
AMERICAN SOCIETY FOR QUALITY CONTROL
FEDERATION OF SOCIETIES FOR COATINGS TECHNOLOGY

Submitted by: Everkem Diversified Products
120 Regent Drive.
Winston-Salem, NC 271023

Date: December 6, 2017

Attn: Matt Lowman

Report No.: 50699-2

REPORT

Lab Sample No:

50699-2 Thermal Seal Gunfoam TS-GF24 (#128352-3021)

PROCEDURE

Sample was tested per AAMA 812 "Voluntary Practice for Assessment of Single Component Aerosol Expanding Polyurethane Foams for Sealing Rough Openings of Fenestration Installations" with the following results:

RESULTS

<u>Section/Test</u>	<u>Sample</u>
9.0 Pressure Build	3.9 psi
10.0 Deflection (6063-T5 Alum.)	0.018"
11.0 Dimensional Stability	
A) 104±4°F/90±5% RH	+1.7%
B) 86±4°F/30±5% RH	+0.4%
C) -4±4°F/Uncontrolled RH	-0.5%

DISCUSSION

Sample meets the ±10% dimensional stability requirement and exhibits low pressure build and deflection values as tested per manufacturers use instructions.

Date Testing Completed: 12/05/2017
Date Test Report Expires: 12/05/2020


DALLAS LABORATORIES, INC.



Lab Test Technician

Analyst: GF, KJ
KWJ:js

DALLAS LABORATORIES, INC.



Kevan W, Jones, Vice President